



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment    | Problem                                                        | Action                                                                            | From     | To       | Remarks |
|-------|------|--------------|----------------------------------------------------------------|-----------------------------------------------------------------------------------|----------|----------|---------|
| 1     | OHP  | co 25        | olr acted                                                      | reset                                                                             | 00:00:00 | 00:05:00 |         |
| 2     | OHP  | CO 26        | olr acted                                                      | reset                                                                             | 04:30:00 | 04:40:00 |         |
| 3     | OHP  | TBS on CO 24 | L BC not running,zssc age stucked due to stone/ belt offcentre | cage made free                                                                    | 23:50:00 | 00:00:00 |         |
| 4     | CHP  | cc 54        | motor tripped in olr                                           | reset                                                                             | 01:25:00 | 01:30:00 | 2 times |
| 5     | CHP  | cc 51        | mpd triped                                                     | reset                                                                             | 03:30:00 | 03:35:00 |         |
| 6     | CHP  | CC 131       | olr acted                                                      | reset                                                                             | 01:10:00 | 01:15:00 |         |
| 7     | CHP  | cc 31        | mpd tripped                                                    | reset                                                                             | 03:35:00 | 03:40:00 |         |
| 8     | WT   | CT2          | not moving,brake problem,one diode damaged                     | diode replaced,run in brake mode find ok,than kept in normal mode given clearance | 01:55:00 | 02:38:00 |         |
| 9     | WT   | OT 3         | D2 tripped                                                     | reset                                                                             | 01:40:00 | 01:45:00 | 3 times |