



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/06/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-25	SLEW OLR TRIP (2TIMES)	RESET DONE	12:00:00	12:40:00	
2	CHP	CC-51	CC-51 MPD TRIP	RESET DONE	12:30:00	12:35:00	
3	CHP	CC-38	REPORTED STOPPING ON ZSS FOUND SS MODULE PROBLEM	MODULE REPLACED WITH NEW ONE THAN OK	08:10:00	08:30:00	