



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/07/2026

Incharge(s): G Eswara Rao

Shift: C

| Sl No | Area | Equipment      | Problem                                   | Action            | From     | To       | Remarks      |
|-------|------|----------------|-------------------------------------------|-------------------|----------|----------|--------------|
| 1     | OHP  | CO 26          | TRIPPED ON OLR                            | RESET DONE        | 01:00:00 | 01:05:00 |              |
| 2     | CHP  | CC 58          | TRIPPED ON OLR                            | RESET DONE        | 03:55:00 | 04:20:00 |              |
| 3     | CHP  | SCR 3 ON CC37  | SLEW NOT TAKINGPLACE/OIL LEVEL LOW        | INFORM TO MECH.   | 23:30:00 | 23:50:00 | PIPE LEAKAGE |
| 4     | CHP  | SCR 9 ON CC213 | BC NOT RUNNING//SIGNAL MISSING            | LT DONE THEN OK   | 23:35:00 | 23:45:00 |              |
| 5     | CHP  | SCR 2 ON CC33  | BC NOT RUNNING/SLEW 30DEGREE LIMIT ACTED  | RELEASED          | 00:20:00 | 00:40:00 |              |
| 6     | CHP  | CC 201         | TRIPPED ON OLR                            | RESET DONE        | 23:25:00 | 23:30:00 |              |
| 7     | CHP  | CC 131         | TRIPPED ON OLR                            | RESET DONE        | 05:35:00 | 05:40:00 |              |
| 8     | WT   | OT 5           | F/R NOT TAKING PLACE/TOP CLAMP LS 7 ACTED | BYPASSED IN SCADA | 03:40:00 | 03:45:00 |              |