



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 30/04/2026

Area: CHP

Equipment	Job
CC 116,117	New control cable laying under progress
CC 13	MD commissioning done and tested.To be put in ckt
Coal complex	Rooms cleaning done
SCR 2,SCR 5	2 NOS YARD MACHINE SHIFTINGS DONE
SCR 5 on CC 33	HT cable old joint sleeve provide by DNW
SCR 3	HT cable jointed by DNW,termination done and charged supply