



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/05/2026

Area: CHP

Equipment	Job
CC 117	2 nos 300W LED bay lamps replaced and ckt problem rectified
SCR 10	Instrumentation sensors maintenance was done
CC 218/219 tunnel	12 nos 30W LED lamps replaced and improved lighting
DE 8	Fan motor meggered and trail run was taken after greasing
CC 105,106 HT I/C,I/C 4	HT panels maintenance done
CC 8	Burnt motor coupling removed