RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 05/11/2026

Area: WT

Equipment	Job
CP-3	COL.NO. 78 PACKING PROVIDED FOR CABLE INSULATION
LC-10A	PLC CHANGED AND TESTED
OT-1 SERIES	MOTOR AND PANEL SIDE PPM DONE
CT-1 AND CT-2	PANEL SIDE PPM DONE