



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 24	LT not working,m4 olr acted	reset	10:05:00	10:20:00	
2	OHP	brc on co 8A	b/w 2 no movement,mechanical problem, hydraulic motor decoupled from shaft	informed mechanical	08:15:00	08:30:00	
3	CHP	cc 104 scr 6	LT not working,track jamming	informed to operation	07:20:00	07:30:00	
4	CHP	CC 39 SCR7	slew not working,jamming	informed operation	07:35:00	07:45:00	
5	CHP	CC 125	olr acted	reset	08:15:00	08:20:00	
6	CHP	CC 37 scr 3	b/c not running in stacking mode	slew done than ok	08:45:00	08:55:00	