वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 01/11/2026

Shift: A

Incharge(s): Amit Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | CO-26 | Reported tripped | OLR acted.Reset done | 08:45:00<br>13:30:00 | 09:00:00<br>13:35:00 | |
| 2 | OHP | WOBR on CO-6A | Cabin adjustment not taking place | PB contact loose at operator cabin.Tightened and tested okay | 09:05:00 | 09:25:00 | |
| 3 | OHP | WOBR on CO-29 | LT not taking place | Wrong complaint | 10:00:00 | 10:10:00 | |
| 4 | OHP | TBS on CO-20 | Luffing not taking place | OLR acted.Reset done | 08:00:00 | 08:15:00 | |
| 5 | CHP | Cc-54 | Reported tripped | OLR acted.Reset done | 08:00:00 | 09:00:00 | |
| 6 | CHP | SCR-9 on CC-104 | Luffing not taking place | PLC glass relay to output TB wire loose.Tightened and tested okay | 09:35:00 | 09:50:00 | |
| 7 | CHP | SCR-7 on CC-40 | Luffing not taking place | OLR acted.Reset done | 11:35:00 | 11:45:00 | |
| 8 | CHP | CC-215 | Reported tripped | OLR acted.Reset done | 09:35:00 | 09:45:00 | |
| 9 | WT | OP-4 | Reported not moving | Breaker tripped.Checked and found bottom pad C clamp damaged.Replaced and tested okay | 10:15:00 | 10:45:00 | |
| 10 | WT | OP-7 | Reported not moving | Reverse limit switch in acted condition.Released and tested okay | 06:30:00 | 06:45:00 | |
| 11 | WT | OC-1A,OAF-1A,OAF-2A | Showing in local | PLC power recycled at LC-9 and tested okay | 12:15:00 | 12:30:00 | |
| 12 | WT | OT-5 | Reported not rotating | Checked and found LS-3 limit not healthy.Bypassed through scada and tested okay | 12:20:00 | 12:35:00 | LS-3 limit to be checked |

वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 01/11/2026

Shift: A

Incharge(s): Amit Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 13 | IOSA | OC-27A | Reported healthy stop | Checked and found no problem.Made to run and found okay | 12:52:00 | 13:00:00 | |