RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 31/10/2026

Area: OHP

Equipment	Job
wbr-2 on co-29	LT m3 motor checked , found ok, gear box is also checked by mechanical , restored LT operation in VFD mode.
Misc.	1) co-11a canopy for BRS is provided. 2) LOSP-2 lighting is improved. 3) co-34a to 36a chute vibrator is replaced. 4)co-66 to 69 chute vibrator base bolts replaced . 5) jh-14 to ocr walkway light and 62 level light is replaced. 6) CBMS and TIS spare motors are verified at LBDS4
co-3a, tt-4, cr-1	motor and panel side ppm is done, cr-1 motor greasing is done at both ends.