RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 31/10/2026

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	Reported tripped	OLR acted.Reset done(2 times)	06:44:00	09:15:00	
2	OHP	WOBR on CO-29	Reported LT not taking place	M-3 OLR acted.LT wheel found stuck	07:05:00	07:15:00	Informed to mechanical
3	OHP	WOBR on CO-25	Luffing not taking place	Up limit found stuck.Made free	12:10:00	12:20:00	
4	OHP	CO-26	Reported tripped	OLR acted.Reset done	09:10:00	09:15:00	
5	OHP	VS-2A	Reported tripped	OLR acted due to jamming.Reset done	09:45:00	09:50:00	
6	OHP	CO-12(C/D)	Reported tripped	MPCB tripped.Made on	09:40:00	09:50:00	
7	CHP	SCR-7 on CC-40	B/C not running	Checked and didn't find any electrical problem	09:25:00	09:40:00	
8	CHP	SCR-4 on CC-111	Slewing not taking place	MCB tripped.Made on.	10:55:00	11:10:00	
9	CHP	CC-215	Reported healthy stop	Drive control MCB tripped.Made on.ZSS cage stuck.ZSS bypassed	11:15:00	11:35:00	ZSS cage to be replaced
10	IOSA	OC-25A	Reported tripped	OLR acted.Reset done(2 times)	10:00:00	13:40:00	