



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/08/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OLR ACTED	RESET DONE	22:55:00	23:00:00	
2	OHP	CO-26	OLR ACTED	RESET DONE	00:45:00 04:45:00	00:50:00 04:50:00	
3	OHP	CO-29	OLR ACTED	RESET DONE	02:05:00	02:10:00	
4	OHP	BRC ON CO-33M	BW-1 NOT RUNNING	FLUID COUPLING PROBLEM INFORMED OPERATION	05:10:00	05:20:00	
5	CHP	CC-52	TRIPPED ON MPD	RESET DONE	04:00:00	04:05:00	