



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/08/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	TRIPPED ON OLR	RESET DONE	07:45:00	07:55:00	
2	OHP	WOBR ON 6A	SLEW NOT STOPPING/STOP PB PROBLEM	PB ADJUSTMENT DONE	07:07:00	07:20:00	NOT MAKING P ROPERLY/ TO BE CHANGED
3	OHP	TBS ON CO 5A	LEFT LUFFING NOT TAKING PLACE	POWER AND CONTROL OFF/MADE ON THEN OK	10:45:00	11:15:00	
4	OHP	CC 54	MPD TRIPPED ON OLR	RESET DONE	13:10:00	13:15:00	