



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/08/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: A

| Sl No | Area | Equipment | Problem                   | Action     | From                             | To                               | Remarks |
|-------|------|-----------|---------------------------|------------|----------------------------------|----------------------------------|---------|
| 1     | OHP  | CO 25     | TRIPPED ON OLR/4TIMES     | RESET DONE | 07:35:00<br>08:55:00<br>12:40:00 | 07:45:00<br>09:05:00<br>12:45:00 |         |
| 2     | CHP  | CC 54     | MPD TRIPPED ON OLR/5TIMES | RESET DONE | 10:30:00                         | 11:40:00                         |         |
| 3     | CHP  | CC 40     | MPD TRIPPED ON OLR        | RESET DONE | 08:00:00                         | 08:05:00                         |         |