



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/09/2026

Area: WT

Equipment	Job
Bed Drain	coal side bed drain kept on running pumps provided by CISF(Fire)
CP 4	Lighting timer kept in circuit
CP 4	Track lifted by railways @ parking zone and tested OK
LC 9	Burnt sump pump replaced with spare @ sump
LC 2A and 2B	OP 1 to OP 8 panel maintenance done