



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/09/2026

Shift: C

Incharge(s): Nagendra Midde,G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OLR ACTED (2TIMES)	RESET DONE	22:45:00	22:55:00	
2	OHP	WOBR ON CO-26	REPORTED LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	02:45:00	03:00:00	
3	OHP	BRC ON CO-30	CT NOT TAKING PLACE FOUND DRIVE SUPPLY TRIPPED	MADE ON	00:20:00	00:30:00	
4	OHP	BRC ON CO-30	B/C NOT RUNNING CJD ACTED DUE TO MECHANICAL PROBLEM	MECHANICAL RECTIFIED THAN CJD OK	02:35:00	02:45:00	
5	OHP	BRC ON CO-30	B/C OLR ACTED	RESET DONE	04:45:00	05:05:00	
6	OHP	CR-1	OLR ACTED	RESET DONE	23:10:00	23:20:00	
7	OHP	VS-2	OLR ACTED	RESET DONE	03:00:00	03:10:00	
8	OHP	TT-3	REPORTED LT NOT TAKING PLACE PCRD POWER CABLE Y PHASE INSULATION DAMAGED	PROPER INSULATED THAN OK	02:45:00	03:30:00	
9	OHP	BRC ON CO-30	B/W-2 NOT RUNNING FLUID COUPLING PROBLEM	INFORMED TO MECHANICAL	01:10:00	01:20:00	
10	OHP	LC-19 ,CM-24	REPORTED NO POWER FOUND FOUND LBDS 4,5 FEEDER-2 TRIP	FEEDER -2 CHARGED THAN OK	02:15:00	02:40:00	
11	CHP	CC-52	MPD TRIP	RESET DONE	01:30:00 23:55:00	01:35:00 00:05:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/09/2026

Incharge(s): Nagendra Midde,G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	WT	OT-4	TANK TEMPRATURE SHOWING HIGH	SENSOR REMOVED FROM TANK	04:30:00	06:00:00	AFTER COMPLETED RACK KEPT IN CIRCUIT