



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/05/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 7A LT	DRIVE TRIP	RESET	20:35:00	20:50:00	
2	OHP	CR3	OLR ACTED	RESET	20:45:00	20:55:00	
3	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	19:20:00	19:25:00	
4	CHP	CC 28	OLR ACTED	RESET	15:20:00	15:30:00	