



वी.एस.पी  
VSP

RASHTRIYA ISPAT NIGAM LIMITED  
VISAKHAPATNAM STEEL PLANT  
RAW MATERIAL HANDLING PLANT  
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/06/2026

Area: WT

| Equipment | Job                                                                                     |
|-----------|-----------------------------------------------------------------------------------------|
| CP-2      | TROLLEY LINE CHECKED AND PROBLEM RECTIFIED NEAR COL. NO 43                              |
| MIS       | ONE VFD DRIVE MADE READY FOR OP-8 AND VECON DRIVE TESTED FOR REPLACEMENT OF D-2 IN OT-3 |
| EOT COAL  | AUX HOIST MOTOR CHECKED ... CABLE REPLACED .. CONTROL PROBLEM RECTIFIED AND TESTED      |