



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/09/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-29	LT not taking place	M-3 tripped due to material jamming.Reset done	17:10:00	17:25:00	
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	18:30:00 20:50:00	18:37:00 21:00:00	
3	OHP	BRC on CO-32	CT not taking place	Chain fallen	19:30:00	19:45:00	Informed to mechanical
4	OHP	TBS on CO-5A	CJD acted.	CJD not fixed properly while changing chute.Fixed properly and tested okay	16:55:00	17:10:00	
5	CHP	SCR-3 on CC-36	LT not taking place	Drive tripped.Reset done	17:40:00 18:05:00	17:55:00 18:20:00	
6	CHP	CC-52	MPD tripped	Reset done	21:10:00	21:15:00	