



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/05/2026

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment            | Problem                                          | Action                            | From                 | To                   | Remarks |
|-------|------|----------------------|--------------------------------------------------|-----------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO 25                | OLR ACTED                                        | RESET                             | 05:20:00             | 05:30:00             |         |
| 2     | OHP  | WBR ON<br>CO 6A      | BREAKER TRIPPED                                  | MADE IT ON                        | 03:00:00             | 03:20:00             |         |
| 3     | OHP  | CO 26                | OLR ACTED                                        | RESET                             | 02:00:00             | 05:10:00             | 3 TIMES |
| 4     | CHP  | SCR 8 ON<br>CC 112   | LT PCRD MPCB TRIPPED                             | MADE IT ON                        | 23:55:00             | 00:10:00             |         |
| 5     | CHP  | SCR 6 ON<br>CC 40 LT | O/T ACTED                                        | RESET                             | 01:00:00<br>01:50:00 | 01:10:00<br>02:00:00 |         |
| 6     | CHP  | SCR 3 ON<br>CC 37 LT | O/T ACTED DUE TO CABLE ZIG ZAG , GUDE<br>PROBLEM | AFTER MECH CLEARANCE WINDING DONE | 02:50:00             | 03:00:00             |         |
| 7     | CHP  | CC 131               | OLR ACTED                                        | RESET                             | 04:40:00             | 04:45:00             |         |
| 8     | CHP  | CC 51                | FEEDING CONV OLR ACTED                           | RESET                             | 03:40:00             | 03:45:00             |         |
| 9     | CHP  | CC 27A T/T           | MPCB TRIP                                        | MADE IT ON                        | 22:30:00             | 22:35:00             |         |