



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 25/09/2026

Area: CHP

Equipment	Job
CC 18,24,21,26	PPM was done
CC 35,S 2	PPM was done
S 3 on CC34	Found 3 nos HT fuses blown, thumping done by DNW and found faulty location of the cable,joint to be done tomorrow
All LCs and CMs	De watering inspected