



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/05/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	OLR acted	reset	23:30:00	23:40:00	
2	OHP	TBS on CO 24	LT not working,M4 OLr acted	reset	03:25:00	03:40:00	
3	OHP	CO 35	OLR acted	reset	04:35:00	04:40:00	
4	OHP	WOBR on CO 25	slewing not working.drive tripped	reset	05:10:00	05:20:00	
5	CHP	CC 31 SCR 1	slew NOT WORKING,drive tripped	reset	00:45:00	00:55:00	
6	CHP	CC 125	olr acted	reset	01:10:00	01:15:00	
7	CHP	CC 51	mpd acted	reset	05:35:00	05:40:00	
8	CHP	CC 51A	pull chord acted	released	03:00:00	03:10:00	
9	WT	OP4	no movement,d3 OLr acted	reset	22:00:00	22:15:00	coupling time
10	WT	OT 3	D1 DRIVE TRIPPED	RESET	05:47:00	05:52:00	