



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/09/2026

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR-1	OLR ACTED	RESET DONE	07:25:00	07:36:00	
2	OHP	RBF-3A (C)	OLR ACTED (3TIMES) DUE TRACK JAMMING	RESET DONE	07:30:00	08:30:00	
3	OHP	CO-26	OLR ACTED	RESET DONE	09:40:00	09:50:00	
4	OHP	TBS ON CO-22	REPORTED LT NOT TAKING PLACE FOUND LT LOCAL MODE	KEPT IN REMOTE MODE THAN OK	09:40:00	09:50:00	
5	OHP	CO-111	MPCB TRIP	MADE ON	13:20:00	13:30:00	
6	CHP	CC-54	OLR ACTED	RESET DONE	08:05:00	08:10:00	
7	CHP	CC-22	STOPPING ON ZSS FOUND ZSS PROBE PROBLEM	PROBE REPLACED THAN OK	08:10:00	08:30:00	
8	CHP	cc-104 scr-9	reported b/c not running found c/s acted	sensors cleaned than ok	12:00:00	12:15:00	
9	CHP	cc-112 scr-8	reported b/c not running found 30 degree limit acted	released than ok	12:30:00	12:45:00	
10	WT	OP-8	REPORTED NOT MOVE FOUND ACB TRIP IN LC-2A	ACB CHARGED THAN OK	09:10:00	09:30:00	