



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/07/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS-21	CJD bypass	CJD, RMU terminations tightened and restored CJD in circuit. TBS Boom run signal Latch has been programmed and indication provided in OCR HMI	22:30:00	23:30:00	
2	OHP	WBR ON CO 29	B/C ZSS PROBE IS HAVING DUST	PROPERLY CLEANED	02:00:00	02:15:00	
3	OHP	CO 26	OLR ACTED	RESET	05:35:00	05:45:00	
4	OHP	AF2	OLR ACTED	RESET	22:20:00	23:05:00	2 TIMES
5	OHP	CO 16	OLR ACTED	RESET	05:40:00	05:45:00	
6	OHP	VS 5A	OLR ACTED	RESET	01:40:00	01:50:00	
7	CHP	CC 131	OLR ACTED	RESET	22:30:00	04:30:00	2 TIMES
8	CHP	CC 54	OLR ACTED	RESET	00:45:00	00:50:00	
9	CHP	VS3	OLR ACTED	RESET	22:30:00	22:40:00	
10	CHP	CC 52 TIS	CHAIN BROKEN	INFORMED TO MECH	01:15:00	01:30:00	
11	CHP	CC 215	OLR ACTED	RESET	04:00:00	04:10:00	
12	CHP	CC 31	OLR ACTED	RESET	22:05:00	22:15:00	
13	CHP	SCR 2 ON CC 33 LT	PCRD DRUM SENSOR ACTED	RESET	23:00:00	23:10:00	
14	CHP	CC 107	OLR ACTED	RESET	04:10:00 05:40:00	04:15:00 05:45:00	