



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/07/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OLR ACTED	RESET DONE	08:30:00	08:40:00	
2	OHP	WOBR ON CO-29	REPORTED LT NOT TAKING PLACE DRIVE TRIP (DUE TO TACK JAMMING)	DRIVE RESET DONE AND INFORMED TO OPERATION	09:05:00	09:20:00	
3	OHP	BRC ON CO-28	REPORTED B/W-2 NOT RUNNING CHECKED AND FOUND GUIDE ROLLER FELL DOWN	INFORMED TO MECHANICAL AND OPERATION	12:55:00	13:10:00	
4	CHP	TT ON CC-26	LT OLR ACTED	RESET DONE	07:30:00	07:40:00	
5	CHP	CC-29 F/G	OLR ACTED	RESET DONE	09:30:00	09:40:00	
6	CHP	CC-125	OLR ACTED (2TIMES)	RESET DONE	12:00:00 13:25:00	12:10:00 13:35:00	