



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/07/2026

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment    | Problem                                           | Action                          | From     | To       | Remarks |
|-------|------|--------------|---------------------------------------------------|---------------------------------|----------|----------|---------|
| 1     | OHP  | CO-26        | OLR ACTED                                         | RESET DONE                      | 08:25:00 | 08:30:00 |         |
| 2     | OHP  | TT-2 C/S     | REPORTED C/S NOT HEALTHY                          | SENSOR CLEANED THAN OK          | 11:40:00 | 11:50:00 |         |
| 3     | OHP  | TBS ON CO-20 | REPORTED NO POWER FOUND ACB AND MAIN CONTROL TRIP | ACB AND MAIN CONTROL ON THAN OK | 07:40:00 | 08:00:00 |         |
| 4     | OHP  | TBS ON CO-7A | REPORTED ALL DRIVES NOT WORKING FOUND ACB TRIP    | ACB MADE ON                     | 11:55:00 | 12:10:00 |         |
| 5     | OHP  | CO-2A ,CO-5A | REPORTED NOT HEALTHY LBSS-1 I/C-2 TRIP            | POWER RE-STORED THAN OK         | 07:30:00 | 08:00:00 |         |
| 6     | CHP  | CC-7 C/S     | NOT HEALTHY FOUND WIRE OPEN IN JB                 | WIRE RE-CONNECTED THAN OK       | 09:15:00 | 09:25:00 |         |
| 7     | CHP  | CC-33 SCR-2  | LT NOT TAKING PLACE PCRD O/T ACTED                | RELEASED THAN OK                | 06:25:00 | 06:45:00 |         |
| 8     | CHP  | CC-33 SCR-2  | LT NOT WORKING E/STOP OPERATED                    | RELEASED THAN OK                | 07:15:00 | 07:35:00 |         |
| 9     | CHP  | SCR-2        | B/C NOT RUNNING SIGNAL MISSING                    | LT FORWARD THAN OK              | 09:25:00 | 09:45:00 |         |
| 10    | CHP  | CC-131       | OLR ACTED                                         | RESET DONE                      | 13:15:00 | 13:25:00 |         |