



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/07/2026

Area: CHP

Equipment	Job
CC 8	PPM was done
CC 57 gallery	3 nos 35W fixtures provided
R 1,SCR 9	Yard machine shifting done
CC 36	Motor replaced,aligned and coupled