



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/08/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs-3 on co-5a	LT not taking place	PCRD over tension acted. released	10:10:00	10:20:00	
2	OHP	co-33m	OLR acted	reset done	08:15:00	08:20:00	
3	CHP	cc-131	TRIPPED ON OLR	RESET DONE	12:40:00	12:45:00	
4	CHP	CC-33 SCR-2	LT NOT WORKING PCRD DRUM SENSOR ACTED	RESET DONE	11:45:00	12:00:00	