



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/07/2026

Shift: C

Incharge(s): G Eswara Rao,M Kailash

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CBMS-1A ON CO-11A	Feedback missing	Power and control made recycled. Then OK	00:00:00	00:05:00	
2	OHP	CO-29	OVERLOAD ACTED	Reset done	03:30:00 05:20:00	03:40:00 05:25:00	
3	OHP	TIS-5 ON CO-25	TIS starting and stopping in between.	Bypassed in program and I/O rack	04:10:00	04:50:00	To be normalised
4	OHP	BRC-2 ON CO-30	HT Transformer fault identified in secondary side.	All connections are opened	22:00:00	00:30:00	slipping side packing provided. to be removed
5	CHP	SCR-3 ON CC-37	LT not working. PCRD tension acted.	Released and made OK	22:30:00	22:40:00	
6	CHP	STK-2 ON CC-106	LT not working. M-2 overload acted	Reset done and made OK	00:55:00	01:05:00	
7	CHP	SCR-8 ON CC-111	CABLE JOB FROM B.SHIFT	Given clearance at 12 30 am	22:00:00	00:30:00	
8	CHP	CC-215	OVERLOAD ACTED	Reset done	04:20:00 05:20:00	04:30:00 05:30:00	
9	CHP	CC-201	OVERLOAD ACTED	RESET DONE	00:10:00	00:20:00	
10	CHP	CC-51	Feeding conveyor MPR acted	Reset done	01:25:00 02:00:00	01:30:00 02:05:00	
11	CHP	CC-131	OVERLOAD acted	Reset done	01:25:00 02:00:00	01:35:00 02:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/07/2026

Incharge(s): G Eswara Rao,M Kailash

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	RG-3	Healthy stop reported	checked and found no electrical problem. Found RG rns damaged. Informed to Mechanical	02:05:00 02:35:00	02:30:00 02:45:00	To be checked further