# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 11/11/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | CC 108 | OLR acted | Reset | 19:20:00 | 21:15:00 | 2 times |
| 2 | OHP | CO 25 | OLR acted | Reset | 21:00:00 | 21:05:00 | |
| 3 | OHP | TBS on CO 7a | Drive trip | Reset | 15:35:00 | 15:50:00 | |
| 4 | OHP | BRC on co 8a | LT M2 trip | Reset | 17:30:00 | 17:56:00 | |
| 5 | OHP | BRC on Co 33m | Drive trip | Reset | 18:50:00 | 19:00:00 | |
| 6 | OHP | BRC on CO 31 | B/C OLR acted | Reset | 19:05:00 | 19:15:00 | |
| 7 | CHP | SCR 5 on CC 32 LT | Drive trip | Reset | 15:00:00 | 15:15:00 | |
| 8 | CHP | SCR 7 On CC 40 B/C | Signal missing | PLC power recycled then ok | 15:30:00 | 17:50:00 | 2 times |
| 9 | CHP | CC 213 Not running | CC 213 to CC 216 programming not there | Programming done | 17:00:00 | 17:30:00 | |
| 10 | CHP | CC 131 | OLR acted | Reset | 19:10:00 | 20:00:00 | 3 times |
| 11 | WT | OP4 D2 | OLR acted | Reset | 17:00:00 | 17:05:00 | |