



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/09/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	23:34:00	23:41:00	
2	OHP	co 25	olr acted	reset	03:55:00	04:05:00	
3	OHP	co 32	stopped in zss fault,belt slipping	informed mechanical and operation	02:15:00	02:30:00	
4	OHP	TBS on Co 7A	rBC stopped in zss,module problem	module replaced	00:30:00	00:55:00	
5	CHP	CC 111 scr4	LT not working,wrong complaint	given cmd from operator cabin	23:45:00	00:00:00	
6	CHP	CC 33 SCR2	LT not working,PCRD drum sensor	released	04:00:00	04:10:00	
7	CHP	CC 54	motor tripped 2 times	reset	23:05:00	23:10:00	