



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/07/2026

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment    | Problem             | Action     | From     | To       | Remarks |
|-------|------|--------------|---------------------|------------|----------|----------|---------|
| 1     | OHP  | TBS ON CO-7A | L/LUFFING OLR ACTED | RESET DONE | 12:00:00 | 12:15:00 |         |