



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2026

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-7A	L/LUFFING OLR ACTED	RESET DONE	23:50:00	00:15:00	
2	OHP	VS-2A	OLR ACTED	RESET DONE	04:10:00	04:15:00	