



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/06/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 28	BC NOT RUNNING/OLR ACTED DUE TO JAMMING	RESET DONE	06:00:00	06:20:00	
2	OHP	WOBR ON CO 29	LT NOT TAKING PLACE/	CHANGED TO DOL MODE THEN OK	08:50:00	09:05:00	TO BE CHEKED IN REMOTE MODE
3	OHP	BRC ON CO 32	HYDROLIC PUMP NOT RUNNING/OIL LEVEL LOW	INFORM TO OPERATION	10:00:00	10:15:00	
4	OHP	BRC 5 ON CO 32	HYDROLIC PUMP NOT RUNNING/IOL LEVEL LOW	INFORM TO OPERATION and MECH.	09:30:00	09:45:00	
5	OHP	CO 26	TRIPPED ON OLR	RESET DONE	10:40:00	10:50:00	
6	OHP	CO 21 YARD CONV.	BRS (JOD) ACTED	RESET DONE	11:35:00	11:45:00	
7	CHP	CC 51	MPD TRIPPED ON OLR	RESET DONE	11:55:00	12:05:00	
8	CHP	CC 54	TRIPPED ON OLR	RESET DONE	06:40:00	06:50:00	
9	CHP	SCR 3 ON CC 37	SLEW and BW NOT WORKING/HYDROLIC IOL PIPE LINE LEAKAGE	INFORM TO MECH.	09:40:00	09:50:00	
10	CHP	CC 43	TRIPPED ON OLR	RESET DONE	11:50:00	12:00:00	
11	CHP	SCR 2 ON CC33	LT NOT TAKING PLACE/PCRD ZSS ACTED	RESET DONE	11:00:00	11:10:00	
12	WT	CP 1	FORWARD /REVERSE NOT WORKING/ACB TRIPPED	ACB MADE ON	13:10:00	13:20:00	COL.91,92



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/06/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	LC 1 and 2B INCMMER 1	BUSCOUPLE MADE OFF AND I/C 1 MADE ON	TESTED OK	08:00:00	08:15:00	