



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/09/2026

Area: WT

Equipment	Job
OP 2	D4 motor found burnt and replaced it spare motor
CP 4 jobs	second side wall, roof sheet and cable trays welding done