



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/06/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-7A	Left luff going down when giving up command	Brake adjustment done by mechanical	14:20:00	14:40:00	
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	14:50:00	15:00:00	
3	CHP	Cc-38 SCR-5	B/C not running	Slewing 30 degree limit acted.	14:45:00	15:00:00	
4	CHP	CC-38 SCR-5	LT not taking place	Drive tripped.Reset done	16:35:00	16:50:00	