



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/06/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	00:45:00	00:55:00	
2	OHP	WBR ON CO 25	SLEW DRIVE TRIP	RESET	03:55:00	04:10:00	
3	OHP	VS 2A	OLR ACTED	RESET	01:00:00	01:10:00	
4	OHP	RSCO 6A CD	OLR ACTED	RESET	02:00:00	02:10:00	
5	CHP	SCR 5 ON CC 38 B/C	30 DEGREE LIMIT ACTED	RESET	22:25:00	22:35:00	
6	CHP	SCR 1 ON CC 31 B/W	STOP PB STUCK	MADE IT FREE	03:15:00	03:25:00	
7	CHP	CC 15 C/S	PROBE CLEANED	THEN OK	22:50:00	23:00:00	
8	CHP	CC 29 ZSS	LOOSE CONNECTION IN MODULE	TIGHTENED	22:55:00	23:05:00	
9	WT	OP4	D3 OLR ACTED	RESET	04:40:00	04:50:00	