



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/06/2026

Area: CHP

| Equipment         | Job                                                                                 |
|-------------------|-------------------------------------------------------------------------------------|
| CC 52,53          | PPM was done                                                                        |
| CC 51 tunnel      | 6 nos LED fixtures replaced. Now all installed lights inside the tunnel are glowing |
| CC 28/29 Gallery  | 4 nos bay lamps replaced and ckt problem rectified                                  |
| CC 12/13 Gallery  | 10 nos LED fixtures replaced and defective fixtures removed                         |
| SCR 8             | HT cable twists removed                                                             |
| CC 39,40,S2,SCR 6 | PPM was done                                                                        |
| SCR 10            | Shifted from CC 213 to CC 106                                                       |