



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/09/2026

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OLR ACTED	RESET DONE	18:35:00	18:45:00	
2	CHP	CC-131	TRIPPED ON OLR (2TIMES)	RESET DONE	19:20:00 20:40:00	19:25:00 20:45:00	
3	CHP	CC32 SCR-5	REPORTED B/C NOT RUNNING IN STACKING MODE FOUND 30DEGREE BIT NOT COMING	SLEW DONE UP TO 30DEGREE THAN OK	15:15:00	15:25:00	
4	WT	OP-2	REPORTED NOT MOVING FOUND ACB TRIP IN LC-2A	MADE ON	20:15:00	20:25:00	
5	WT	CT-1	IN-HALL OLR ACTED	RESET DONE	20:30:00	20:40:00	