



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/09/2026

Shift: B

Incharge(s): Nagendra Midde, G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR on CO 6A B/C	Power MCCB trip	Made it on	18:10:00	18:20:00	
2	OHP	BRC on CO 28 B/W	Power MCCB trip	Reset	18:30:00	18:40:00	
3	OHP	WBR on CO 29	B/C C/S not resetting	Bypassed	18:45:00	19:00:00	Informed to Instrumentation
4	OHP	CO 50	OLR acted	Reset	15:00:00	15:10:00	
5	OHP	RSCO 6A CD	Mpcb trip due to Track jamming	Reset	16:00:00	16:10:00	
6	OHP	RBF 3a CD	OLR acted due to track Jamming	Reset	19:40:00	19:50:00	
7	CHP	CC 58	OLR acted	Reset	19:00:00	19:15:00	
8	CHP	CC 54	OLR acted	Reset	20:10:00	20:20:00	
9	CHP	CC 112	DE C/S acted due to rain	Probe cleaned then ok	16:00:00	16:15:00	
10	IOSA	TBS on OC 14a	M4 motor got burnt and drive to M4 cable 2 cores problem	Disconnected	20:00:00	20:30:00	