RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 22/10/2026

Area: CHP

Equipment	Job
CC 9	Motor replacement job under progress
CC 9	Vaccume contactor replaced,OLR module bus bars replaced with jumpers,damaged finger contacts replaced
SCR 8,9,10	Instrumentation sensors and Belt scale units maintenance done
Reclaiming streams	All Hoists UP limits tested
CC 125	BRS Canopy fabricated and welded ,kept in ckt
CC 45,113A,132,Transfer car	PPM was done
Coal complex,LC 17	Rooms cleaning done