



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/07/2026

Area: OHP

Equipment	Job
co-5a zss	module, probe changed and restored zss in circuit.
co-5a zss	module, probe changed and restored zss in circuit.
rco-1a	motor and panel side ppm is done.
rco-1a	motor and panel side ppm is done.
co-12 to co-14	spare chute vibrator fixed and trail run taken.
co-12 to co-14	spare chute vibrator fixed and trail run taken.
rsco-10a belt drive panel outgoing	Running inspection defect checked and terminations tightened.
rsco-10a belt drive panel outgoing	Running inspection defect checked and terminations tightened.
brc-3 on co-33m	shifted to co-34
brc-3 on co-33m	shifted to co-34