



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/06/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	23:55:00	00:20:00	2 TIMES
2	OHP	CO 26	OLR ACTED	RESET	01:40:00	01:45:00	
3	CHP	SCR 1 ON CC 31 LUFF	OIL LEVEL LOW	INFORMED TO OPRN	02:45:00	03:00:00	
4	CHP	SCR 1 ON CC 31 LUFF	OLR ACTED	RESET	22:50:00	23:00:00	
5	CHP	SCR 6 ON CC 104	LT TRACK JAMMING	INFORMED TO OPRN	22:50:00	23:00:00	
6	CHP	SCR 2 ON CC 33	B/W TYRE COUPLING PROBLEM	INFORMED TO MECH	00:20:00	00:40:00	
7	CHP	CC 52	FEEDING CONV OLR ACTED	RESET	04:00:00	05:00:00	3 TIMES
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	04:40:00	04:50:00	