RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 03/11/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR on CO 25 B/C	C/S acted Due to Jamming	Informed to OPRN	22:20:00	22:35:00	
2	OHP	BRC on CO 31 B/W1	Chain problem	Informed to OPRN	23:40:00	23:55:00	
3	OHP	BRC on CO 32	Yard Interlock ZSS Probe cable cut	Rejoint	00:15:00	00:30:00	
4	OHP	BRC on CO 32 LT	Skew acted	Informed to OPRN	05:15:00	05:30:00	
5	CHP	CC 215 ZSS	Cage stuck	Made it free	04:15:00	04:25:00	
6	CHP	SCR 5 on CC 32 LT	O/T acting due to PCRD cable fell down	Winding done Properly	00:30:00	01:00:00	
7	CHP	CC 54	OLR acted	Reset	01:50:00	03:00:00	2 times
8	CHP	CC 203	OLR acted	Reset	22:30:00	22:40:00	
9	CHP	CC 203 BRS	Loose connection in module	Tightened	23:00:00	23:10:00	