वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/11/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	olr acted	reset	22:05:00	22:10:00	2 times
2	OHP	CO 29	olr acted	reset	22:40:00	22:45:00	
3	OHP	BRC on CO 31	b/c not running,olr acted	reset	02:15:00	02:25:00	
4	OHP	TBS on CO 22	LT not working,OT acted	OT released	05:15:00	05:30:00	
5	OHP	cc 107	stopped in ZSS,conveyor overloaded	informed operation	05:50:00	05:55:00	
6	CHP	CC 35 S2	LT not working,M1 tripped	reset	02:50:00	03:00:00	
7	CHP	cc 131	mpd acted	reset	03:15:00	03:20:00	
8	IOSA	L and T wobr	bc not running,pc acted	Pc released	22:45:00	23:00:00	