वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 08/11/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 13 ZSS	Probe cable got cut	Rejoined	05:10:00	05:25:00	
2	OHP	CO 25	OLR acted	Reset	01:10:00	01:45:00	2 times
3	OHP	CO 26	OLR acted	Reset	02:55:00	03:05:00	
4	OHP	VS2	OLR acted	Reset	02:00:00	02:00:00	
5	OHP	CO 66	Output relay got stuck	Made it free	23:40:00	23:55:00	
6	CHP	CC 131	OLR acted	Reset	01:45:00	01:50:00	
7	CHP	CC 215	OLR acted	Reset	03:10:00	03:20:00	
8	CHP	CC 32	OLR acted	Reset	04:00:00	04:15:00	