



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/07/2026

Area: OHP

Equipment	Job
co-23 t/e area, brc-3 on co-34 stair case area	lighting is improved.
co-23 t/e area, brc-3 on co-34 stair case area	lighting is improved.
co-21,22	Fuse TB's are installed, CJB field devices high was routed through them.
co-21,22	Fuse TB's are installed, CJB field devices high was routed through them.
co-14,tt-1,10,13 belt and carriage ; tbs-4 on co-5a, co-5a	motor and panel side ppm is done. TT-1 pcrd cable unwinding done and winding done back onto drum.
co-14,tt-1,10,13 belt and carriage ; tbs-4 on co-5a, co-5a	motor and panel side ppm is done. TT-1 pcrd cable unwinding done and winding done back onto drum.
vs-1 to co-50 chute vibrator	failed/ burnt vibrator is replaced and tested.
vs-1 to co-50 chute vibrator	failed/ burnt vibrator is replaced and tested.
co-36,47 hoists	ppm is done. co-36 GLS rectified and restored in circuit.
co-36,47 hoists	ppm is done. co-36 GLS rectified and restored in circuit.