



वी.एस.पी  
VSP

RASHTRIYA ISPAT NIGAM LIMITED  
VISAKHAPATNAM STEEL PLANT  
RAW MATERIAL HANDLING PLANT  
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/07/2026

Area: OHP

| Equipment              | Job                                                                                                    |
|------------------------|--------------------------------------------------------------------------------------------------------|
| co-19,23,24            | Fuse TB's are installed, CJB field devices high was routed through them.                               |
| co-19,23,24            | Fuse TB's are installed, CJB field devices high was routed through them.                               |
| co-13a h/e hoists      | ppm is done                                                                                            |
| co-13a h/e hoists      | ppm is done                                                                                            |
| vs-1 fan               | fan key slot got damaged, installed a spare fan, sound observed from NDE side, kept under observation. |
| vs-1 fan               | fan key slot got damaged, installed a spare fan, sound observed from NDE side, kept under observation. |
| co-13a,rsc0-6a,14a,14b | motor and panel side ppm is done.                                                                      |
| co-13a,rsc0-6a,14a,14b | motor and panel side ppm is done.                                                                      |
| co-53 h.e, 56 h.e,     | lighting is improved                                                                                   |
| co-53 h.e, 56 h.e,     | lighting is improved                                                                                   |