



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/09/2026

Area: OHP

Equipment	Job
brc-4 on co-8a	Oil cooler Fan Feeder Healthy was bypassed at IO rack. removed bypass and checked interlock
co-32	pullchord cable was damaged during JCB cleaning, rejoin done and restored in circuit.
tt-4 pcrd cable	spare cable is used for full length and slip ring maintenance is done.
wbr-3 on co-25 pcrd motor	motor was having water accumulated inside, cleaned and restored pcrd operations.