



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/05/2026

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment        | Problem              | Action             | From     | To       | Remarks |
|-------|------|------------------|----------------------|--------------------|----------|----------|---------|
| 1     | OHP  | TBS ON CO 7A LT  | DRIVE TRIPPED        | RESET              | 10:20:00 | 10:30:00 |         |
| 2     | OHP  | TT3              | OLD JOINT GOT RUBBED | PROPERLY INSULATED | 12:50:00 | 13:10:00 |         |
| 3     | CHP  | SCR 10 ON CC 105 | AFTER DNW CLEARANCE  | MACHINE CHARGED    | 06:00:00 | 07:45:00 |         |
| 4     | CHP  | CC 28            | OLR ACTED            | RESET              | 08:30:00 | 08:40:00 |         |
| 5     | CHP  | CC 131           | OLR ACTED            | RESET              | 11:55:00 | 12:00:00 |         |
| 6     | CHP  | CC 130 TIS       | OLR ACTED            | RESET              | 09:10:00 | 09:15:00 |         |
| 7     | CHP  | CC 51A           | OLR ACTED            | RESET              | 09:25:00 | 09:30:00 |         |