



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/10/2026

Area: OHP

Equipment	Job
af-8	checking under progress along with ETL
co-5	motor and panel side ppm is done
co-20 head end BSS	Slotted base prepared and bss position adjusted and restored in circuit.
co-29	pull chord fault isolated and restored in circuit.